

CERTIFICATE

KEMA No.: 2123583.01



Issued to:
Applicant:

Pipelife Nederland B.V.
Flevolaan 7
1601 MA Enkhuizen
The Netherlands

Manufacturer/Licensee:
Pipelife Nederland B.V.
Flevolaan 7
1601 MA Enkhuizen
The Netherlands

Product : Conduit systems for cable management
Trade name : PIPELIFE
Types : Rigid conduit systems;
POLVALIT 5/8"VSV, 3/4"VSV, 1"VSV, 1 1/4"VSV, 1 1/2"VSV and 2"VSV
POLVALIT Low Friction 5/8"VSV and 3/4"VSV

The product and any acceptable variation thereto is specified in the Annex to this certificate and the documents therein referred to.

KEMA hereby declares that the above-mentioned product has been certified on the basis of:

- a type test according to the standard KEMA 24D-10:2008;
- an inspection of the production location according to CENELEC Operational Document CIG 021
- a certification agreement with the number 900427

KEMA hereby grants the right to use the KEMA-KEUR certification mark.

The KEMA-KEUR certification mark may be applied to the product as specified in this certificate for the duration of the KEMA-KEUR certification agreement and under the conditions of the KEMA-KEUR certification agreement.

This certificate is issued on: 29 April 2009 and expires upon withdrawal of one of the above mentioned standards.

KEMA Quality B.V.

drs. G.J. Zoetbrood
Managing Director

H.R.M. Barends
Certification Manager

ACCREDITED BY
THE DUTCH COUNCIL
FOR ACCREDITATION



© Integral publication of this certificate is allowed

SPECIFICATION OF THE CERTIFIED PRODUCT**Product data**

product : Conduit systems for cable management
trade name : PIPELIFE
types : Rigid conduit systems: POLVALIT and POLVALIT Low Friction

Product data - type POLVALIT

material : PVC compound (VSV)
resistance to compression : 3
resistance to impact : 4
lower temperature range : 4
upper temperature range : 1
resistance to bending : 1
resistance to flame propagation : 1
tested conduits : 5/8"VSV and 2"VSV
certified conduits : 5/8"VSV, 3/4"VSV, 1"VSV, 1 1/4"VSV, 1 1/2"VSV and 2"VSV

Product data - type POLVALIT Low Friction

material : PVC compound (VSV) with inside a low friction layer.
resistance to compression : 3
resistance to impact : 4
lower temperature range : 4
upper temperature range : 1
resistance to bending : 1
resistance to flame propagation : 1
certified conduits : 5/8"VSV and 3/4"VSV

TESTS**Test requirements**

KEMA 24D-10:2008

Test result

The test results are laid down in KEMA test file 2123583.01.

Remarks

This KEMA-KEUR certificate is based on and supersedes KEMA-KEUR certificates no. 993033.05.

Conclusion

The examination proved that all test requirements were met.

Tested by : R. van Daalen

Checked by : A.A. Mackenbach

Factory location

Pipelife Nederland B.V.
Flevolaan 7
1601 MA Enkhuizen
The Netherlands